

# FDA TEST REPORT

For

**N95 Face Masks** 

Model: N/A

Brand: N/A

Report No.: ENC2003192GZ39E1

Date of Issue: Mar. 20, 2020

Prepared For

King Year Printing and Packaging Company Limited

No.30 LongHua Branch RD, Wentang Industry Zone, Dongcheng District,

Dongguan

Prepared By

East Notice Certification Service Co., Ltd.

1/F, Haohui Commercial Building, Zhuji Street, Dongpu Town, Tianhe District,

Guangzhou City, China

TEL: +86-20-2331 4234

FAX: +86-20-8256 8534



fer only to the sample(s) tested unless otherwise stated and the sample(s) are retained for 30 days only. The document is x be reproduced except in full with our prior written permission. The document is available on request and the brief sessable and confirmed at http://www.enc-lab.com.

1/F, Haohui Commercial Building, Zhuji Street, Dongpu Town, Tianhe District, Guangzhou City Tel:+86-020-2331 4234 E-mail: enc@ enc-lab.com



Report No.: ENC2003192GZ39E1

Page 1 of 4

## TEST REPORT ASTM F2101-2019

### Medical face masks — Requirements and test methods

Report reference No. ...... ENC2003192GZ39E1

Tested by .....: 5.1.2e

Review by (+ Signature). .....:

Approved by (+ signature) ...... 5.1.2e



Name ...... East Notice Certification Service Co., Ltd.

Address ...... 1/F, Haohui Commercial Building, Zhuji Street, Dongpu Town,

Tianhe District, Guangzhou City, China

Testing location .....: Same as above

Application

Dongcheng District, Dongguan

Manufacturer

Dongcheng District, Dongguan

Test specification

Standard ...... : ASTM F2101-2019

Establishment ID.: ..... E2003166

Procedure deviation ...... N/A

Non-standard test method ...... N/A

Test Report Form/blank test report

Test Report Form No. ..... ENCASTMF2101-A2

TRF originator. .... : ENC

Test item

Description ...... N95 Face Masks

 Brand name
 N/A

 Model
 N/A

 Classification
 Type I



fer only to the sample(s) tested unless otherwise stated and the sample(s) are retained for 30 days only. The document is the reproduced except in full with our prior written permission. The document is available on request and the brief sessable and confirmed at http://www.enc-lab.com.

1/F, Haohui Commercial Building, Zhuji Street, Dongpu Town, Tianhe District, Guangzhou City Tel:+86-020-2331 4234 E-mail: enc@ enc-lab.com



Report No.: ENC2003192GZ39E1

Page 2 of 4

#### Testing

Test Side Either Side 

BFE Area Tested ~40 cm<sup>2</sup>

Delta P Flow Rate...... 8 L/min

of 4 hours.

Negative Monitor Count...... <1 CFU

MPS...... 3.0 am

#### Summary of testing

The BFE test is performed to determine the filtration efficiency by comparing the upstream bacterial control counts to downstream test article counts. A suspension of Staphylococcus aureus was aerosolized using a nebulizer and delivered to the test article at a constant flow rate and challenge delivery. The challenge delivery is maintained at 1.7 - 2.7 x 10<sup>3</sup> colony forming units (cfu) with a mean particle size (MPS) at 3.03 m ± 0.33 m. The aerosol droplets were drawn through a six-stage, viable particle, Andersen sampler for collection. This procedure allows a reproducible bacterial challenge to be delivered to test materials. This test method complies with ASTM F2101-2019.

The Delta P test determines the breathability by measuring the differential air pressure on either side of the test article using a manometer, at a constant flow rate. The Delta P test was designed to comply with MIL-M-36954C. Section 4.4.1.2.

All test method acceptance criteria were met. Testing was performed in compliance with US FDA good manufacturing practice (GMP) regulations 21 CFR Parts 210, 211 and 820.



fer only to the sample(s) tested unless otherwise stated and the sample(s) are retained for 30 days only. The document is x be reproduced except in full with our prior written permission. The document is available on request and the brief sessable and confirmed at http://www.enc-lab.com.

1/F, Haohui Commercial Building, Zhuji Street, Dongpu Town, Tianhe District, Guangzhou City Tel:+86-020-2331 4234 E-mail: enc@ enc-lab.com



Report No.: ENC2003192GZ39E1

Page 3 of 4

#### Test results:

Sample No.	Bacterial filtration efficiency (BFE), (%)	Differential pressure (Pa/cm²)	Splash resistance Pressure (kPa)	Microbial cleanliness (cfu/g)	Verdict
9	98.4	23.4	Not required	17.8	PASS
2 🍫	98.1	23.0	Not required	4 17.9	PASS
3	98.3	23.1	Not required	17.6	PASS
4	98.2	23.4	Not required	18.1	PASS
5 🍨	98.5	23.2	Not required	4 18.2	PASS

The filtration efficiency percentages were calculated using the following equation:

$$\%BEF = \frac{C \Gamma T}{C} x \ 100$$

C = Positive control average

T = Plate count total recovered downstream of the test article

Note: The plate count total is available upon request



fer only to the sample(s) tested unless otherwise stated and the sample(s) are retained for 30 days only. The document is x be reproduced except in full with our prior written permission. The document is available on request and the brief sessable and confirmed at http://www.enc-lab.com.


1/F, Haohui Commercial Building, Zhuji Street, Dongpu Town, Tianhe District, Guangzhou City Tel:+86-020-2331 4234 E-mail: enc@ enc-lab.com



Report No.: ENC2003192GZ39E1 Page 4 of 4

# APPENDIX A PHOTO(S) OF PRODUCT





#### -- END OF REPORT---



fer only to the sample(s) tested unless otherwise stated and the sample(s) are retained for 30 days only. The document is x be reproduced except in full with our prior written permission. The document is available on request and the brief sessable and confirmed at http://www.enc-lab.com.

1/F, Haohui Commercial Building, Zhuji Street, Dongpu Town, Tianhe District, Guangzhou City

Tel:+86-020-2331 4234 E-mail: enc@ enc-lab.com